

Certificate of Product Approval

Certificate Number: 1330h-(cl-1) Issue: 01



Tanda (UK) Limited

Fourth Floor 30-31 Furnival Street London EC4A 1JQ United Kingdom

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Control and Indicating Equipment TX7004

(refer to Appendix for details)

Standards

EN 54-2:1997 + A1:2006 EN 54-4:1997 + A1:2002 + A2:2006

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

E Mattie-Suleiman

21 April 2017 Date of Issue 21 April 2017

Date of First Issue

LPCB LPCB



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com







Appendix to Certificate No: 1330h-(cl-1) Issue: 01 Tanda (UK) Limited

Certified Product	Description	LPCB Ref.No.
TX7004	1 to 4 loop Intelligent Addressable Control and Indicating Equipment	1330h/01
	Incorporating the following modules:	
	7010200004 TX7004 Mother Board	
	7020100022 TX7004 Main Board	
	7010700017 TX7004 Loop Board	
	7010400011 TX7004 Power Management Board 7010600019 TX7004 Communication Board	
	7010400012 TX7004 Power Wiring Board PDF-150-27.5 Power Supply Unit	
	7021300007 TX7004 Key Board	
	7021300007 TX7004 Rey Board 7020800009 TX7004 Led Board	
	7010300010 TX7004 Regional Display Board	
	814400002 TX6940E Printer Module	
	Contified with the following entires with requirements from ENEA 2.	
	Certified with the following options with requirements from EN54-2:	
	7.8 Output to fire alarm device(s)	
	7.10.1 Output to fire protection equipment - Type A	
	7.11 Delays to outputs	
	7.12.1 Dependencies on more than one alarm signal. Type A	
	7.12.2 Dependencies on more than one alarm signal -Type B 7.13 Alarm counter	
	9.5 Disablement of each address point	
	10 Test condition	
	10 lest condition	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

E Mattie-Suleiman

21 April 2017

21 April 2017

Date of Issue

Date of First Issue





This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com







Appendix to Certificate No: 1330h-(cl-1) Tanda (UK) Limited

Certified Product	Description	LPCB Ref.No.
	Note:	
	The scope of the approval does not include the operation of the network functionality	
	2. The product approval does not constitute compliance with the fire detection and alarm system requirements of EN54-13.	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

E Mattie-Suleiman

21 April 2017

21 April 2017

Verifier

Date of Issue

Date of First Issue





This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com





Issue: 01