Hacousto Holland bv		
Industrieweg 87		
2651BC Berkel & Rodenrijs		



4E-GPIO installation and user guide

Author:

7. Marking



0560-CPR-152190001/00

Hacousto Holland BV Industrieweg 87, 2651BC, Berkel en Rodenrijs The Netherlands 4EVAC

4EVAC Compact voice alarm system: C500

Note: Conditions of use, Suitable for Indoor applications

Product is in compliance with the Directive 89/106/EEC of the council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Regulation (EU) No 305/2011 of the European Parliament and Council of March 2011.

EN54-4:1999+A1+A2 EN54-16:2008

Power supply equipment Voice alarm control and indicating equipment for fire detection and fire alarm systems for buildings

ESSENTIAL REQUIREMENTS	DECLARED PERFORMANCE	HARMONISED STANDARDS
EN54-4 Mandatory functions	PASS	EN54-4:1999+A1:2003/A2:2006
EN54-16 Mandatory functions	PASS	54-16:2008
Options with requirements:		
Audible warning	PASS	54-16:2008, 7.3
Phased evacuation	PASS	54-16:2008, 7.5
Manual silence of the voice alarm condition	PASS	54-16:2008, 7.6.2
Manual reset of the voice alarm condition	PASS	54-16:2008, 7.7.2
Voice alarm condition output	PASS	54-16:2008, 7.9
Indication of faults related to the voice alarm zones	PASS	54-16:2008, 8.4
Voice alarm manual control	PASS	54-16:2008, 10
Emergency microphone(s)	PASS	54-16:2008, 12
Redundant power amplifiers	PASS	54-16:2008, 13.14
C500 - Marking r02	27-02-2017	Page 1 of 2



4E-GPIO installation and user guide

Author: DD

