

CERTIFICATE OF COMPLIANCE

Certificate Number 20160920-EX6960
Report Reference EX6960-20110729
Issue Date 2016-SEPTEMBER-20

Issued to: FIREPRO SYSTEMS LTD
6, KOUMANDARIAS STREET
& SPYROU ARAOUZOU
TONIA COURT NO. 2, 1ST FLOOR 3036
54080 LIMASSOL CYPRUS

**This is to certify that
representative samples of**

Fixed Condensed Aerosol Extinguishing System Units
Pre-Engineered, FirePro Aerosol Generating Fire Extinguishing
System Units, Models FP-20SE, FP-20T, FP-40S, FP-40T, FP-
80S, FP-80T, FP-100S, FP-200S, FP-500S, FP-1200, FP-1200S,
FP-1200T, FP-1200TS, FP-2000, FP-2000S, FP-2000T, FP-
2000TS, FP-3000, FP-3000S, FP-3000T, FP-3000TS, FP-4200T,
FP-4200TS, FP-5700, FP-5700S, FP-5700T, and FP-5700TS
with 20, 40, 80, 100, 200, 500, 1200, 2000, 3000, 4200, and
5700 grams respectively. The units have operating temperatures
of -65°F (-54°C) to 130°F (54°C). The units are designed for total
flooding protection against Class A, ordinary combustibles, Class
B flammable liquid fires, with or without Class C involvement,
occurring within an enclosure.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 2775, Fixed Condensed Aerosol Extinguishing System Units
Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20160920-EX6960
Report Reference EX6960-20110729
Issue Date 2016-SEPTEMBER-20

Issued to: FIREPRO SYSTEMS LTD
6, KOUMANDARIAS STREET
& SPYROU ARAOUZOU
TONIA COURT NO. 2, 1ST FLOOR 3036
54080 LIMASSOL CYPRUS


This is to certify that representative samples of Aerosol-Generating Fire Extinguishing System Units
See Addendum page

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ULC/ORD-C2775-12, Fixed Condensed Aerosol Extinguishing System Units


Additional Information: See the ULC Online Certification Directory at www.ulc.ca for additional information

Only those products bearing the ULC Listing Mark should be considered as being covered by ULC's Listing and Follow-Up Service.

The ULC Listing Mark generally includes the following elements: the symbol ULC in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by ULC; and the product category name (product identifier) as indicated in the appropriate ULC Directory.

To confirm the status, validate the above information via the online directory.

Look for the ULC Listing Mark on the product.



Joseph Hosey, General Manager, Director of Sales - Canada

UNDERWRITERS LABORATORIES OF CANADA INC.

Any information and documentation involving ULC Mark services are provided on behalf of Underwriters Laboratories of Canada Inc. (ULC) or any authorized licensee of ULC. For questions, please contact a local ULC Customer Service Representative at <http://ul.com/aboutul/locations/>




CERTIFICATE OF COMPLIANCE

Certificate Number 20160920-EX6960
Report Reference EX6960-20110729
Issue Date 2016-SEPTEMBER-20

This is to certify that representative samples of the product as specified on this certificate were tested according to the current ULC requirements.

Pre-Engineered, FirePro Aerosol Generating Fire Extinguishing System Units, Models FP-20SE, FP-20T, FP-40S, FP-40T, FP-80S, FP-80T, FP-100S, FP-200S, FP-500S, FP-1200, FP-1200S, FP-1200T, FP-1200TS, FP-2000, FP-2000S, FP-2000T, FP-2000TS, FP-3000, FP-3000S, FP-3000T, FP-3000TS, FP-4200T, FP-4200TS, FP-5700, FP-5700S, FP-5700T, and FP-5700TS with 20, 40, 80, 100, 200, 500, 1200, 2000, 3000, 4200, and 5700 grams respectively. The units have operating temperatures of -65°F (-54°C) to 130°F (54°C). The units are designed for total flooding protection against Class A, ordinary combustibles, Class B flammable liquid fires, with or without Class C involvement, occurring within an enclosure.



Joseph Hosey, General Manager, Director of Sales - Canada

UNDERWRITERS LABORATORIES OF CANADA INC.

Any information and documentation involving ULC Mark services are provided on behalf of Underwriters Laboratories of Canada Inc. (ULC) or any authorized licensee of ULC. For questions, please contact a local ULC Customer Service Representative at <http://ul.com/aboutul/locations/>

